



PRODUCT DATA SHEET

LIGHTNING PROTECTION AND EARTHING SYSTEM COMPONENTS


Code: 63 01 002

Description: St/tZn element "Γ" (gamma) of earth electrode type "E"™

ed.02/2021 Page 1 of 2

Application

Element "Γ" (gamma), part of earth electrode type "E"TM.



Element "Γ" (gamma)

					4.0
Techr	11001	Che	ract	OFIC	H.C.C.

Dimensions (LxWxH) 750x500x500 mm

One plate of 500x500x3 mm dimensions and one plate of 750x500x3 mm dimensions, with all the needed accessories (bolts, nuts, washers,

coinference that connection angles)

reinforcement bar, connection angles).

Core material / Coating material Steel / Zinc Zinc coating weight >500 gr/m²
Type of coating method Hot dip

Bolts / nuts material Stainless steel grade V2A

 $\begin{array}{ll} \text{Electrical resistivity} & <0,25 \; \mu\Omega\text{m} \\ \text{Tensile strength} & 290 - 510 \; \text{N/mm}^2 \end{array}$

Installation instructions

Installation Buried in ground, embedded in concrete

Can be connected in ground with SSt (Stainless Steel), St/tZn

Can be connected in concrete with Cu, Cu-A (copper alloy), Cu/eSn, SSt (Stainless Steel), St/eCu, St/tZn

Connection to conductor By stainless steel clamp ELEMKO code 62 66 108 (provided)

Connection to Element "Π" (pi), ELEMKO code 63 01 001 to form earth electrode type "E"TM.

Comply with

The component complies with standard IEC EN 62561-2 "Lightning protection system components (LPSC) – Part 2: Requirements for conductors and earth electrodes".

Manufacturing Quality Control

Manufacturing quality control according standard ISO 9001

Country of Origin

Greece

Unit: piece / Package: 1 piece

See following applications of the earth electrode.














PRODUCT DATA SHEET LIGHTNING PROTECTION AND EARTHING SYSTEM COMPONENTS

Code: 63 01 002


Description: St/tZn element "Γ" (gamma) of earth electrode type "Ε"™

ed.02/2021 Page 2 of 2



Installation of earth electrode type "E"™. Embedded in concrete.

The electrode should be supported by suitable fasteners (e.g. part number ELEMKO 61 03 025) so as to be elevated at least 5 cm from the bottom of the pit, in order to be completely embedded in concrete and to avoid any electrochemical corrosion due to the contact to different materials (concrete, soil).



Installation of earth electrode type "E"™. Burried in ground.

We reserve the right to introduce changes in the component due to technical evolution.

